



REQUEST FOR FORMAL WRITTEN PRICE QUOTATION FORM

**Procurement from R30 000, 00 up to a transaction value of R200 000, 00 (including Vat).
(For publication on Lesedi Local Municipality Website and Notice Board)**

THE SUPPLY, DELIVERY AND OFF-LOADING OF STREET LIGHT LAMPS ON AN AS AND WHEN REQUIRED BASIS

DATE OF ADVERTISEMENT	07 March 2017
DATE OF CLOSING	15 March 2017@12h00
DETAILS OF BIDDER	
FULL NAME	
ADDRESS OF BIDDER	
ID NUMBER (SOLE PROPRIETOR) COMPANY OR CC NUMBER	
REGISTRATION NUMBER (PTY) LTD	
TAX REFERENCE NUMBER	
VAT REGISTRATION NUMBER (IF ANY)	
CONTACT PERSON	
ALTERNATIVE CONTACT PERSON	
TELEPHONE NUMBER	
CELL PHONE NUMBER	
FAX NUMBER	
CIDB NUMBER (IF ANY)	

Must be completed in full

INTRODUCTION

Street light lamps are used in the Lesedi Local Municipality area of supply for public lighting applications. Quality of the lamps is very important as failure could result in serious consequences and affect the safety and security of LLM communities. The implication to suppliers is that the Lesedi Local Municipality will only purchase street light lamps that comply with the relevant SANS specifications and bears the mark.

1 Scope

This contract calls for the supply, delivery and offloading of street light lamps on an as and when required basis for an amount not exceeding R200 000 (VAT included) and up until June 2017, or whichever comes first. Details are indicated on the following schedules.

2 Normative References

The following documents contain provisions that, through reference in the text, constitute requirements of this specification. At the time of publication, the editions indicated were valid. All standards and specifications are subject to revision, and parties to agreements based on this specification are encouraged to investigate the possibility of applying the most recent editions of the documents listed below.

SANS 60662:2003:	High-pressure sodium vapour lamps
SANS 60529:	Enclosure for electrical equipment. (Classified according to the degree of protection that the enclosure provides)
SANS 60239:	Lamp holders and lamp holder adaptors (Schedule No 9)
SANS 475:	Luminaires for interior lighting, street lighting and flood lighting - Performance requirements
SANS 62035:2003:	Discharge lamps (excluding fluorescent lamps) - Safety specifications

3 Definitions and Abbreviations

The terms, definitions and abbreviations of specifications as listed in Normative References shall apply to this specification.

4 Quantities

Due to the uncertainty and fluctuation of the LLM requirements, no indication can be given as to the quantities of the above-mentioned items which will be required under this contract. The supplier/s will therefore be required to supply the requirements in such quantities as may be required by the LLM from time to time. When supplies are required, the LLM will endeavor to place orders, on an as and when required basis, as far in advance as possible.

5 REQUIREMENTS OF STREET LIGHT LUMINAIRES

All lamps shall all comply with the following minimum specification:-

5.1 High Pressure Sodium lamps

High pressure sodium lamps shall comply with SANS 60662/IEC 60662

Rated power (W)	Base	Shape	Lamp Voltage (V)	Lamp Current \pm 5% (A)	Colour Temperature(Kelvin)	Minimum Lamp Output (Lumen)	Initial Output	Rated Life (hrs) @ 70% initial output
70 (Internal ignitor)	E27	Elliptical	90	1.0	2000	5 600		12000
100	E40	Elliptical	100	1.2	2000	9 500		12000
150	E40	Tubular	100	1.8	2000	14 500		12000

6 TECHNICAL INFORMATION (LAMPS)

The tenderer shall complete the following information schedules. Failure to complete the schedules may lead to disqualification of the tender.

LAMP TYPE	
	High Pressure Sodium
Rated power/type	70 W/I HPS E
Manufacturer	
Luminous efficacy of lamp (lm/W)	
Colour temperature (Kelvin)	
Initial luminous flux output (lm)	
Luminous flux at 12000 hours @ 10hrs/start (% of initial)	
Survival factor at 12000 hours @ 10 hrs/start (%)	
Rated life of lamp at 70% of initial output @ 10hrs/start (hrs)	

7 Guarantee

Suppliers shall guarantee each lamp for the respective minimum period as specified in clause 5. Lamps which fail before the end of the respective minimum period must be replaced free of charge. Suppliers shall be responsible for collecting failed lamps from, and delivering replacements to LLM.

8 Packing and marking

All lamps shall be carefully packed to prevent damage or deterioration during transport, handling and storage.

Each lamp shall be individually packed in a container, which may be a box, wrapper or similar, and which shall be marked with the manufacturer's name or trademark, lamp wattage, cap type, lamp type and quality mark. If the lamps are wrapped, the outer wrappers shall be large enough that they will not unfurl on their own.

9 Documentation

Full technical data, descriptive literature, catalogues if applicable, circuit diagrams and copies of test certificates certifying compliance with the relevant standard(s) of items offered must accompany the tender documentation.

Annexure A – Stock Items

Item	Stock Code	Short Description	Long Description
		Lamp_SL_70W HPS Discharge lamp_Internal Ignitor (E)	Lamp, Street light, 70W High Pressure Sodium Vapour, Discharge Lamp with internal ignitor (E).

Annexure B – Pricing Schedule

Item	Description	Manufacture and Model	Unit Price (Excl. Vat)	Max Delivery Period (Weeks)
	Lamp, Street light, 70W High Pressure Sodium Vapour, Discharge Lamp with internal ignitor (E).			

Name of Company: _____

Contact Person : _____

Telephone No : _____

Fax/E-mail : _____

The following information must be submitted with the quotation, failure in submitting these documents will result in a quotation being disqualified:

- Original tax clearance certificate/ Pin
- Forms listed below (Evaluation Criteria)
- Latest Municipal Account
- Letter of good standing
- CSD registration report/ supplier number

Evaluation Criteria: 80/20 Preference point system as presented in the Preferential Procurement Policy Framework Act no 5 of 2000, for this purpose MBD 2, MBD 4, MBD 6.1 MBD 8, MBD 9 and the Clearance certificate for water & lights can be downloaded on our website on the following link: www.lesedilm.gov.za/key/scm. MBD forms should be scrutinized, completed and submitted together with your quotation. All objections and complaints must be lodge within 14 days and in writing to the municipal's manager's office.

All bidders must ensure that they are registered on the National Treasury Central Supplier Database via the following link: business.support@csd.gov.za. No business will be conducted with any person who is not this database.

NB: Bidders who did not submit an original certified copy of their BBEE Certificate will not be allocated preference points and will be evaluated on price.