



LESEDI

Local Municipality / Plaaslike Munisipaliteit

QUOTATIONS/TENDERS ARE HEREBY REQUESTED IN ACCORDANCE WITH THE SCM REGULATIONS SECTION 18 OF THE LOCAL GOVERNMENT MUNICIPAL FINANCE MANAGEMENT ACT 56 OF 2003, FOR THE PURCHASE OF ITEM/S THAT COULD BE ABOVE R30 000.00

QUOTATIONS MUST BE SUBMITTED IN SEALED ENVELOPES TO Mr PAUL MALGAS OFFICE AT FINANCE DEPARTMENT ,LESEDI OFFICES ,CNR H.F VERWOERD AND DU PREEZ STREET HEIDELBERG 1438, ON OR BEFORE 19 AUGUST 2008 @12H00. ALL ENQUIRIES SHOULD BE REFERRED TO Mr DENNIS LOCKER@ 016 340 4523.

DEPARTMENT: FIRE AND RESCUE

DATE: 13 August 2008

ITEM DESCRIPTION: DECONTAMINATION UNIT

Specifications.

The Decontamination unit must comprise of the following:

- Portable fold up decontamination showers x 3 (three) they must consist of a material that is resistant to chemicals. All three (3) showers provided with a crisscross water flow pattern, the 2nd and third to have crisscross water flow pattern and hand shower. Decontamination showers to have a catchments or containment pools at the bottom for containment of contaminated chemicals after showering. Decontamination showers to have shower curtains that engulf the entire shower with a Zip able shower curtain or Velcro material. The showers must have opening flaps on the Sides for washing assistance and emergency assistance.
- Third shower be enclosed for personnel showering and disrobing. The personal shower not to have any openings on the sides.

- Decontamination showers to have a water supply and connections to supply the showers with water at a rate of not more than 40 LPM. The connections are to be adaptable to 25 mm bush line fire hose and there couplings.
- Decontamination showers must have dimensions of at least 1900mm in height, and 1200mm width all sides.
- All showers are to be installed with a shut off valve at the shower point or at least 5 meters from the shower.
- 3 x Disposable pools made of PVC and lined with poly ethylene lining or equivalent chemical resistant material, welded seams that ensure no leaking and a frame made from stainless steel or similar material.
to meet NFPA or local OHS Regulations.
- 3 x over pack drums to be supplied 210 liter or more.
- 1 x HAZMAT electric water pump, 220 V – 85 LPM to pump out pools.
- 3 x Decontamination waste pools with dimensions of a minimum of 1200mm by 1200 mm. must be either inflatable or collapsible.
- All showers and pools to be supplied with a carrying duffle bag.

Name of Company: _____ Contact person: _____

Telephone No : _____ Fax/E-mail: _____

The following information must be submitted with the quotation:

- ❖ Original tax clearance certificate
- ❖ Forms listed below (Evaluation Criteria)

Evaluation Criteria :80/20 Preference point system as presented in the preferential procurement policy framework Act no 5 of 2000, for this purpose MBD 2,MBD 4 and MBD 6.1 forms are obtainable at no cost from Mr Paul Malgas @ Procurement Office should be scrutinized ,completed and submitted together with your quotation.

**P.J. VAN DEN HEEVER
MUNICIPAL MANAGER**

